

Test Report Summary

Report Number: 260618137GZU-001

Report Date: 2026-08-07

Appendix C: Summary of Test Results

On the basis of the tests undertaken, the sample(s) described below were tested against the referenced specification(s)/standard(s). This summary forms part of the full test report and should be read together with the complete report.

Applicant Name & Address:

ZHONGSHAN TOPTEK SECURITY TECHNOLOGY CO., LTD
No.11 Lian East Street Lianfeng, XiaoLan Town,
Zhongshan City, Guangdong Province, China

Product Description:

Lever Handle

Ratings & Principal Characteristics:

EN 1906:2012 classification

4	7*	-	B	0	4	0	B
---	----	---	---	---	---	---	---

* Durability extended to 500,000 cycles: at-rest deviation 0.40 deg at 200,000 and 0.80 deg at 500,000 cycles; corrosion Grade 4 (240 h); fire resistance Grade B.

Models/Type References:

LHEU001, LHEU002, LHEU003, LHEU004, LHEU005

Brand Names:

TOPTEK

Specification(s)/Standards:

EN 1906:2012 Building hardware - Lever handles and knob furniture - Requirements and test methods

Testing Laboratory & Address:


Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Room 4103 & 4203, No. 63, Punan Road,
Huangpu District, Guangzhou, China

Date of Tests:

Mechanical: 2026-06-26 to 2026-08-05
Fire resistance: 2026-03-30 (timber composite door); 2026-03-31 (steel door)

Test Report Number(s):

260618137GZU-001, dated 2026-08-07 (mechanical)
260119007SHF-006, dated 2026-05-26 (132 min timber composite door)
260119007SHF-008, dated 2026-05-26 (260 min steel door)



Signature

Name: Ziqing Chen

Position: Technical Supervisor

Date: 2026-08-07