Test Report Summary


Report Number: 260618137GZU-002

Report Date: 2026-08-07

Appendix C: Summary of Test Results

On the basis of the tests undertaken, the sample(s) described below were tested against the referenced specification(s)/standard(s). This summary forms part of the full test report and should be read together with the complete report.

Applicant Name & Address:	ZHONGSHAN TOPTEK SECURITY TECHNOLOGY CO., LTD No.11 Lian East Street Lianfeng, XiaoLan Town, Zhongshan City, Guangdong Province, China
Product Description:	Lever Handle
Ratings & Principal Characteristics:	**EN 1906:2012 classification** 3 7 - B 0 4 0 B 200,000 cycles; 0.40 deg at-rest deviation after durability test; corrosion Grade 4 (240 h salt spray); fire resistance Grade B.
Models/Type References:	LHEU001, LHEU002, LHEU003, LHEU004, LHEU005
Brand Names:	TOPTEK
Specification(s)/Standards:	EN 1906:2012 Building hardware - Lever handles and knob furniture - Requirements and test methods. EN 1634-1:2014+A1:2018; EN 1363-1:2020 (fire resistance).
Testing Laboratory & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch (mechanical): Room 4103 & 4203, No. 63, Punan Road, Huangpu District, Guangzhou, China. Shanghai Fengxian Branch (fire): Plant 5, No. 6958 Daye Road, Fengxian District, Shanghai, China.
Date of Tests:	Mechanical: 2026-06-26 to 2026-08-05 Fire: 2026-03-30 (timber composite doorset) Fire: 2026-03-31 (steel doorset)
Test Report Number(s):	260618137GZU-002, dated 2026-08-07 (mechanical) 260119007SHF-006, dated 2026-05-26 (timber composite doorset: 132 min integrity and insulation, no failure) 260119007SHF-008, dated 2026-05-26 (steel doorset: 260 min integrity, no failure; insulation not evaluated)



Signature

Name: Ziqing Chen

Position: Technical Supervisor

Date: 2026-08-07

This Test Report Summary is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client, in accordance with the agreement, for any loss, expense or damage occasioned by the use of this test report summary. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this summary are relevant only to the sample(s) tested. This summary does not imply that the material, product, or service is or has ever been under an Intertek testing program.